

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION**  
**CERTIFICATE**

NO. 060

DATE: 17/06/2025

It is certified that an inspection team headed by DMO G.B. Nagar from CMO Office inspected the R.L INTERNATIONAL SCHOOL, VILL- BISRAKH, SECTOR-1, GREATER NOIDA, on 13-06-2025 and on the basis of Water Test Report (Attached) Letter No-695/Testing/73 date-09-05-2025 of 120 MLD WATER TREATMENT PLANT LAB U.P JAL NIGAM, GHAZIABAD certified that the R.L INTERNATIONAL SCHOOL, has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T.Govt.

**This certificate is valid for One Year.**

*Handwritten signature*

Signature with Seal: .....  
Name : Dr Narendra Kumar  
Designation : Chief Medical Officer  
Name & Address of the Office/Department:.  
CMO Office Sector-39 G.B Nagar

To

The Principal,  
R.L INTERNATIONAL SCHOOL,  
VILL- BISRAKH, SECTOR-1, GREATER NOIDA,  
Gautam Budh Nagar



**OFFICE OF THE EXECUTIVE ENGINEER GANGA JAL PROJECT UNIT,  
U.P. JAL NIGAM (URBAN) 120 MLD W.T.P. LABORATORY,  
PRATAP VIHAR, GHAZIABAD-201009**

Letter No. 695 / 4225 / 73 Dated 09/05/2025

To,  
Chairman  
R.L. International School  
Village Bisrakh, Sector-1,  
Greater Noida, U.P.

Sub :- Physical and Chemical analysis of water sample

Dear Sir

The water analysis report for the water sample (01 No.) sent along with your letter No. --- / --- Dated 02.05.2025 the physical and chemical analysis report is enclosed with this letter.

1- R.O. Water Sample From R.L. International School :- 1 No.  
Village Bisrakh, Sector-1, Greater Noida, U.P.

Total :- 1 No.

Enclosers : As Above.

  
Executive Engineer



# 120 MLD WATER TREATMENT PLANT LAB U.P. JAL NIGAM, GHAZIABAD

TRNo.002132

Letter No.- 695 /

Testing / 73

Dated : 09/05/2025

## DRINKING WATER ANALYSIS REPORT

Sample Sealed : Yes  
Name of person Collected Sample : Sh. Mukesh Yadav  
Date & Time of Sample Collection : 02.05.2025  
Particulars/Source of Sample : R.O. Water Sample From R.L. International School  
Village Bistrakh, Sector -1, Greater Noida, U. P.  
Date of receipt of sample at Lab : 02.05.2025  
Sender Ref. No. : ---- / ---- / Dated 02.05.2025  
By Chairman  
R.L. International School  
Village Bistrakh, Sector -1, Greater Noida, U. P.

Laboratory analysis Ref. No. : PC-3888

Date: 05.05.2025

Test Results: Physico-Chemical Characteristics As per IS 10500 : 2012 as Amendment No. 2

Sl.No.	Characteristic	Expressed as	Analysed result	Acceptable limit	Permissible limit
1	2	3	4	5	6
1	Turbidity	NTU	0.82	1	5
2	pH	-	7.12	6.5 to 8.5	No relaxation
3	Total Dissolved Solids	mg/l	72.00	500	2000
4	Total Hardness (as CaCO <sub>3</sub> )	mg/l	46.00	200	600
5	Chloride (as Cl)	mg/l	9.99	250	1000
6	Sulphate (as SO <sub>4</sub> )	mg/l	8.00	200	400
7	Fluoride (as F)	mg/l	0.42	1.0	1.5
8	Nitrate (as NO <sub>3</sub> )	mg/l	BDL	45	No relaxation
9	Calcium (as Ca)	mg/l	11.22	75	200
10	Magnesium (as Mg)	mg/l	4.36	30	100
11	Iron (as Fe)	mg/l	BDL	1.0	No relaxation
12	Residual Chlorine	mg/l	Nil	0.2	1.0

- Note :- (i) Figures in Col-5 are the limits up to which drinking water is acceptable to the consumers.  
(ii) Figures in excess of Col-6 render the water not acceptable, but still may be tolerated (up to the limit indicated in Col-6) in the absence of alternative and better source.  
(iii) The water sample is not collected by us.  
(iv) BDL- Below Detection Limit.

Test Conducted By

( For M/S Pooja Construction Co.)

COUNTER SIGNED BY

J. E.

A. E.

Executive Engineer